



وزارة العدل

الاستدراج رقم (٣٤/ش/ل/٢٠٢٢)

شراء وصيانة أجهزة UPS

ترغب وزارة العدل بإعادة إستدراج شراء وصيانة أجهزة UPS فعلى المناقصين الراغبين في شراء نسخة من وثائق الشراء مراجعة وزارة العدل (أمين سر لجنة الشراء الرئيسية/ لوازم و خدمات استشارية) للحصول على وثائق الشراء مقابل مبلغ (٢٥) دينار غير مسترده ولغاية الساعة الواحدة بعد الظهر يومياً، آخر موعد للحصول على وثائق الشراء يوم الخميس الموافق (٢٠٢٣/٠٣/٠٢)، وآخر موعد لإيداع العروض مغلقة في صندوق العطاءات لدى قسم المشتريات الساعة الثانية عشر ظهراً يوم الخميس الموافق (٢٠٢٣/٠٣/٠٩)، تفتح العروض في يوم الخميس الموافق (٢٠٢٣/٠٣/٩) الساعة الثانية عشر ظهراً .

١. تقديم كفالة دخول العطاء بنسبة (٣%) من قيمة عرض السعر الاجمالي المقدم ،على شكل كفالة بنكية او شيك بنكي مصدق وتكون باسم "معالي وزير العدل بالإضافة لوظيفته".
٢. تقديم رخصة مهن سارية المفعول.
٣. تقديم سجل تجاري.
٤. تقديم شهادة تسجيل ضريبة المبيعات.
٥. تقديم كفالة حسن تنفيذ بنسبة (١٠%) من قيمة الإحالة النهائية من المتعهد المحال عليه العطاء لمدة تغطي مدة التوريد .
٦. غرامة التأخير هي (٠,٥%) عن كل اسبوع او جزء من الأسبوع من قيمة الاحالة النهائية.
٧. الالتزام الكامل ببنود نظام المشتريات الحكومية رقم ٨ لسنة ٢٠٢٢ وتعديلاته.
٨. مدة التوريد خلال شهر من تاريخ توقيع أمر الشراء .
٩. سيتم إحالة الاستدراج على أسس سعرية بعد استيفاء المواصفات والشروط الواردة في وثائق الشراء .
١٠. يقدم المناقص العرض على وثائق الشراء وفي مغلف مغلق ويثبت اسم الشركة ورقم الاستدراج مع التوقيع والختم على كل وثيقة بما فيها الكتالوجات إن وجدت .
١١. مدة صلاحية عرض السعر وكفالة دخول العطاء (٩٠) يوماً .
١٢. كتابة رقم الهاتف والفاكس بشكل واضح لاعتماده في المخاطبات الرسمية.

واقبلوا الاحترام،،،

Single Phase UPS 1.6 KVA Qty (3)	
INPUT	
Rated power	1600 VA
Voltage	230 ± 10V
Voltage tolerance	230 V ±20%
Frequency	50 / 60 Hz ±5
Frequency tolerance	50 Hz ±5% / 60 Hz ±5%
Power factor	>0.90
Current distortion	≤5%
BY PASS	
Voltage tolerance	230 ± 10V
Frequency tolerance	Frequency selected ±5%
OUTPUT and INVERTER OUTPUT	
Rated power	1600 VA
Crest factor (I _{peak} /I _{rms})	3 : 1
Waveform	Sinusoidal
Frequency	Selectable: 50 Hz or 60 Hz or self-learning
Voltage distortion with non-linear load	≤3 %
Voltage distortion with linear load	<2%
BATTERIES	
Long life	At least 10 years lifetime
ENVIRONMENTAL	
Communication	USB / DB9 with RS232 and contacts / Slot for communications interface
Protections	Overcurrent - short circuit - overvoltage - undervoltage - temperature - excessive low battery
Line-Interactive/Smart Active efficiency	90%
Noise (at 1 m)	<50 [bBA] (ECO Mode)
Operating temperature	0 °C - +40 °C
Relative humidity	5-95% non-condensing
Standards	European directives: L V 2014/35/EU low voltage; EMC 2014/30/EU electromagnetic compatibility -- Directive and Standards: Safety IEC EN 62040-1; EMC IEC EN 62040-2; RoHS compliant -- Classification in accordance with IEC 62040-3 VFI - SS - 111

Single Phase UPS 6 KVA Qty (2)

INPUT	
Rated power	6000 VA
Voltage	230 ± 10V
Voltage tolerance	230 V ±20%
Frequency	50 / 60 Hz ±5
Frequency tolerance	50 Hz ±5% / 60 Hz ±5%
Power factor	>0.90
Current distorsion	≤5%
BY PASS	
Voltage tolerance	230 ± 10V
Frequency tolerance	Frequency selected ±5%
OUTPUT and INVERTER OUTPUT	
Rated power	6000 VA
Crest factor (Ipeak/Irms)	3 : 1
Waveform	Sinusoidal
Frequency	Selectable: 50 Hz or 60 Hz or self-learning
Voltage distortion with non-linear load	≤3 %
Voltage distortion with linear load	<2%
BATTERIES	
Long life	At least 10 years lifetime
ENVIRONMENTAL	
Communication	USB / DB9 with RS232 and contacts / Slot for communications interface
Protections	Overcurrent - short circuit - overvoltage - undervoltage - temperature - excessive low battery
Line-Interactive/Smart Active efficiency	90%
Noise (at 1 m)	<50 [bBA] (ECO Mode)
Operating temperature	0 °C - +40 °C
Relative humidity	5-95% non-condensing
Standards	European directives: L V 2014/35/EU low voltage; EMC 2014/30/EU electromagnetic compatibility -- Directive and Standards: Safety IEC EN 62040-1; EMC IEC EN 62040-2; RoHS compliant -- Classification in accordance with IEC 62040-3 VFI - SS - 111

The image shows four handwritten signatures in black ink, arranged horizontally from left to right. The signatures are stylized and cursive, with varying lengths and flourishes. The first signature is the longest, followed by a shorter one, then a very short one, and finally a medium-length one on the far right.

شراء وصيانة أجهزة UPS

Bill of Quantity:

Item	Description	Qty	U. Price	T. Price
1	UPS 1.6 KVA (محكمة صلح الجيزه)	3		
2	UPS 6 KVA (محكمتي بداية مادبا وبداية عجلون)	2		
3	صيانة جهاز UPS الرئيسي الخاص بمبنى محكمة التمييز	1		
Total				

الشروط الخاصة:

- يلتزم المناقص بتوريد المواد المطلوبة خلال شهر من توقيع امر الشراء.
- تحتسب غرامة التأخير عن التوريد بنسبة مقدارها 0.5% من قيمة الإحالة النهائية عن كل أسبوع تأخير او جزء من الاسبوع.
- يلتزم المناقص بتوريد الأجهزة وتركيبها بالمواقع المحددة من قبل الوزارة.
- يلتزم المناقص بصيانة الأجهزة التي تحتاج صيانة بمواقعها.
- يتم دراسة العروض المقدمة على أساس مقارنة الأسعار بالإحالة للسعر الأقل.
- يلتزم المناقص بتعبئة الأسعار على جدول الكميات أعلاه.
- مواد العطاء أعلاه قابلة لتجزئة الإحالة على مستوى المادة.
- يحق للمناقص التقدم لأي من المواد المطلوبة والصيانة او لجزء منها على ان يلتزم بالكميات المطلوبة لكل مادة.
- يحق للمناقص طلب زيارة ميدانية لفحص الجهاز المراد اجراء صيانة له بالتنسيق مع الوزارة.

وزارة العدل
مديرية كمبوديا العولمات